



**PAMBANSANG MUSEO NG PILIPINAS**  
**NATIONAL MUSEUM OF THE PHILIPPINES**

**Republic of the Philippines**  
**Bids and Awards Committee**

**BID BULLETIN**  
**NO. 2023-01**

Project Title:

**PREVENTIVE MAINTENANCE OF AIR-CONDITIONING SYSTEM  
AT REGIONAL NATIONAL MUSEUM OF THE PHILIPPINES (NMP)  
BUILDINGS F.Y. 2023**

Item No. 1 :

Revision on Section VII. Technical Specification and  
Terms of Reference of the Bidding Documents


**TECHNICAL SPECIFICATIONS**

Original	Revised
Coverage of Technical Works:  Item B. No. 6&7  6. In the event that a running equipment fails due to damage/defective Minor parts such as bearing, capacitor, fuse, filter drier, breaker, contactor, thermistor, copper tubes, rubber insulation, sensors, the Contractor shall supply & install the replacement parts to reinstate the unit to its normal operation.  7. In the event that a running equipment fails due to damage/defective Major parts such as electrical controller, motherboard, compressor, fan motor, drain pump also including re processing of the system, the National Museum shall supply the replacement parts but the Contractor shall undertake the necessary installation/repairs to	Coverage of Technical Works:  Item B. No. 6&7  6. In the event that a running equipment fails due to damage/defective Minor parts such as bearing, capacitor, fuse, filter drier, breaker, contactor, thermistor, copper tubes, rubber insulation, sensors, the Contractor shall supply & install the replacement parts <b>within thirty (30) days</b> to reinstate the unit to its normal operation.  7. In the event that a running equipment fails due to damage/defective Major parts such as electrical controller, motherboard, compressor, fan motor, drain pump also including re processing of the system, the National Museum shall supply the replacement parts but the Contractor shall undertake the necessary installation/repairs to

reinstate the unit to its normal operation.	<b>immediately once the replacement units are available and delivered at the site to</b> reinstate the unit to its normal operation.
---	--

Done this 19<sup>th</sup> day of April, 2023

Prepared by:



**EDWIN J. DELA ROSA**  
Head-BAC Secretariat

Approved by:



**ATTY. MA. ROSENNE M. FLORES-AVILA**  
Chairperson  
Bids and Awards Committee

ENCL: NONE

CC: FMD

BACSEC/DELA ROSA/ILAR

National Museum of the Philippines Complex, Rizal Park, Ermita, Manila 1000  
inquiry@nationalmuseum.gov.ph  
www.nationalmuseum.gov.ph  
(+63-2) 8298-110