



PAMBANSANG MUSEO NG PILIPINAS
NATIONAL MUSEUM OF THE PHILIPPINES

BID BULLETIN NO. 2023 – 01

Project Title : Refill of Argonite Cylinders of Fire Suppression System at NMFA Building

Item No. 1 : Clarifications;

1. Similar projects pertains to Installation, Repair or Upgrading of Argonite Type Fire Suppression System. Since “IG-55” Fire Suppression System uses Argonite chemical as agent, “Rehabilitation and Replacement of 10 Empty IG55 Cylinders for Laoag SS Control Building” is considered as similar.
2. Based on our market study, 60 Calendar days duration is enough to complete the project. In case there were delays that were beyond the control of the Contractor, we can issue Time Extension or Suspension to compensate the time consumed.
3. For easier identification, we will put tags for the 37 cylinders of Argonite gas that were below standard pressure.

Done this 8th day of August 2023.

Prepared by:

Approved by:

(SGD)

EDWIN J. DELA ROSA
Head, BAC Secretariat

(SGD)

ATTY. MA. ROSENNE M. FLORES-AVILA
Chairperson
Bids and Awards Committee

ENCL: NONE
CC: NONE
BACSEC/DELAROSA/NLV